LEOCH PU358V50(358.4V50Ah)

PU358V50



LEOCH Provides Safe and Efficient LFP Battery Solutions.

LEOCH PU series adopt high safety LFP cell, with intelligent BMS management system independently developed by LEOCH, safe and reliable, excellent performance, stability and reliability, suitable for three-phase UPS backup system.

Features

- · Safest lithium battery technology
- · Eco-friendly
- · 20 Years Designed service life
- · Can/RS485 Communication output for monitoring
- Achieve up 32 BMU in cascade communication • Interal cell balancing, Passive equalization, the
- maximum equalization current up to 300 mA
- \cdot High-precision cell voltage and temperature acquisition: ±3 mV,±1 $^\circ\text{C}$
- \cdot Fan control circuit and interface, realize heat dissipation inside the module

PACK Style




Peformance data

Time(min)	10	15	20	30	60	
Constant Power(kw)	79.8	70	49	35.2	17.8	
Constant Current(A)	245	200	150	100	50	









System specifications	
Case Material	SPCC
Cell Type	Prismatic LiFePO ₄
Terminal Type	M8
IP Grade	IP21
Basic performance	
Nominal Voltage	358.4V
Nominal Capacity	50Ah
Energy	17.92KWh
Self Discharge	≤2%/Month
Cell Capacity	50Ah
Cycle Life	2500 times(1C/1C)
Size	1000*600*1500mm
Weight	380 Kg

Charge performance	
Rated Charge Current	25A
Maximum Charge Current	50A
Rated Charge Voltage	380.8-386.4V
Balancing Voltage	>380.8V


Discharge performance		
Max Output Power	79.8KW	
Standard Discharge Time	70KW@15min	
Rated Discharge Cut-off Voltage	313.6V	
Minimum Discharge Cut-off Voltage	296.8V	
Short Circiut Current	Approx.4000A	

Temperature and humidity			
-20-65°C			
0-45°C			
-5-35°C			
-20-65°C			
≤95%R.H			


Other	
Communication	CAN/RS485/LAN
Dry Contact	Yes
System Parallels	≤15
Screen	Optional
Thermal Management	Air Cooling



Discharge Performance at 25°C



Temperature effects on capacity at 1C



Cautions

- 1. Do NOT short circuit, crush or disassemble
- 2. Do NOT heat or incinerate.
- 3. Do NOT immerse in any liquid.

4. Store at 50% capacity. Recharge every 6 months. The storage area should be clean, cool, dry and ventilated.

5. Disconnect charging source prior to connecting or disconnecting battery terminals.

6. Do NOT dispose of batteries in a fire as they can explode.

7. Do NOT open, alter, or mutilate batteries. Released electrolyte is harmful to skin and eyes. It may be toxic. 8.Do NOT mix different types and brands of lithium-ion batteries.

9. Do NOT dispose in trash, follow local regulations and manufacturer's instruction.


10.See installation instructions before connecting to the supply.

11. The battery cabinet receives power from more than one source. Disconnection of all DC sources is required to De-energize this unit before installing or servicing. Wait 5 minutes before opening the unit.


12. Do NOT install on or over combustible surfaces

- 13.Refer to manual before servicing
- 14.Do NOT touch bare terminals.

Charge and Discharge at 25°C,0.5C



Cycle life with DOD at 25°C, 1C/1C





Rack PU358V50(S) PU358V50--without HMI, PU358V50(S)-with HMI

Data above is recommended and the picture is only for battery effect display, Leoch reserve the final right of explanation. ©LEOCH.All rights reserved. Trademarks and logos are the properly of LEOCH and its affiliates unless otherwise noted.Subject to revisions without prior notice E&OE.