LEOCH BU409V100(409.6V100Ah) BU409V100



LEOCH Provides Safe and Efficient LFP Battery Solutions.

LEOCH BU series adopt high safety LFP cell, with intelligent BMS management system independently developed by LEOCH, safe and reliable, excellent performance, stability and reliability, suitable for three-phase UPS backup system.

Features

- · Safest lithium battery technology
- · Eco-friendly
- · 20 Years Designed service life
- · Can/RS485 Communication output for monitoring
- Achieve up 32 BMU in cascade communication
- \cdot Interal cell balancing, Passive equalization, the maximum equalization current up to 300 mA
- \cdot High-precision cell voltage and temperature acquisition: ±3 mV,±1 $^\circ\text{C}$
- Fan control circuit and interface, realize heat dissipation inside the module

PACK Style




Peformance data

Time(min)	30	60	120	180	300
Constant Power(kw)	78.4	39.2	19.6	13.1	7.8
Constant Current(A)	200	100	50	33.3	20

Size









System specifications		
Case Material	SPCC	
Cell Type	Prismatic LiFePO ₄	
Terminal Type	M8	
IP Grade	IP21	
Basic performance		
Nominal Voltage	409.6V	
Nominal Capacity	100Ah	
Energy	40.96KWh	
Self Discharge	≤2%/Month	
Cell Capacity	100Ah	
Cycle Life	2500 times(1C/1C)	
Size	1000*600*2000mm	
Weight	545 Kg	

Charge performance	
Rated Charge Current	50A
Maximum Charge Current	100A
Rated Charge Voltage	435.2-441.6V
Balancing Voltage	>435.2V


78.4KW
78.4KW@30min
358.4V
339.2V
Approx.4500A

Temperature and humidity			
Discharge Temperature	-20-65°C		
Charge Temperature	0-45°C		
Storage Temperature	-5-35°C		
Transportation Temperature	-20-65°C		
Operating Humidity	≤95%R.H		


Other	
Communication	CAN/RS485/LAN
Dry Contact	Yes
System Parallels	≤15
Screen	Optional
Thermal Management	Air Cooling



Discharge Performance at 25°C



Temperature effects on capacity at 1C



Cautions

- 1. Do NOT short circuit, crush or disassemble.
- 2. Do NOT heat or incinerate.
- 3. Do NOT immerse in any liquid.

4. Store at 50% capacity. Recharge every 6 months. The storage area should be clean, cool, dry and ventilated.

5. Disconnect charging source prior to connecting or disconnecting battery terminals.

6. Do NOT dispose of batteries in a fire as they can explode.

7. Do NOT open, alter, or mutilate batteries. Released electrolyte is harmful to skin and eyes. It may be toxic. 8.Do NOT mix different types and brands of lithium-ion batteries.


9. Do NOT dispose in trash, follow local regulations and manufacturer's instruction.

10.See installation instructions before connecting to the supply.


11. The battery cabinet receives power from more than one source. Disconnection of all DC sources is required to De-energize this unit before installing or servicing. Wait 5 minutes before opening the unit. 12. Do NOT install on or over combustible surfaces 13. Refer to manual before servicing


14.Do NOT touch bare terminals.

Charge and Discharge at 25°C,0.5C



Cycle life with DOD at 25°C, 1C/1C





Rack BU409V100(S) BU409V100–Without SBMS, BU409V100(S)-With SBMS

Data above is recommended and the picture is only for battery effect display, Leoch reserve the final right of explanation. ©LEOCH.All rights reserved.Trademarks and logos are the properly of LEOCH and its affiliates unless otherwise noted.Subject to revisions without prior notice E&OE.