LEOCH BU614V200(614.4V200Ah)

BU614V200




LEOCH Provides Safe and Efficient LFP Battery Solutions.

LEOCH BU series adopt high safety LFP cell, with intelligent BMS management system independently developed by LEOCH, safe and reliable, excellent performance, stability and reliability, suitable for three-phase UPS backup system.

Features

- · Safest lithium battery technology
- · Eco-friendly
- · 20 Years Designed service life
- · Can/RS485 Communication output for monitoring
- Achieve up 32 BMU in cascade communication • Interal cell balancing, Passive equalization, the
- maximum equalization current up to 300 mA
- \cdot High-precision cell voltage and temperature acquisition: ±3 mV,±1°C
- \cdot Fan control circuit and interface, realize heat dissipation inside the module

PACK Style



Peformance data

Time(min)	60	120	180	300	600	
Constant Power(kw)	121.5	61.3	40.9	24.5	12.28	
Constant Current(A)	200	100	66.7	40	20	

Size





System specifications		
Case Material	SPCC	
Cell Type	Prismatic LiFePO ₄	
Terminal Type	M10	
IP Grade	IP21	
Basic performance		
Nominal Voltage	614.4V	
Nominal Capacity	200Ah	
Energy	122.88KWh	
Self Discharge	≤2%/Month	
Cell Capacity	200Ah	
Cycle Life	2500 times(1C/1C)	
Size	1000*600*2000mm	

Charge performance	
Rated Charge Current	100A
Maximum Charge Current	200A
Rated Charge Voltage	652.8-662.4V
Balancing Voltage	>652.8V

1144 Kg

Weight


Discharge performance		
Max Output Power	121.5KW	
Standard Discharge Time	121.5KW@60min	
Rated Discharge Cut-off Voltage	537.6V	
Minimum Discharge Cut-off Voltage	508.8V	
Short Circiut Current	Approx.4000A	

Temperature and humidity		
-20-65°C		
0-45°C		
-5-35°C		
-20-65°C		
≤95%R.H		


Other	
Communication	CAN/RS485/LAN
Dry Contact	Yes
System Parallels	≤15
Screen	Optional
Thermal Management	Air Cooling



Discharge Performance at 25°C



Temperature effects on capacity at 1C



Cautions

- 1. Do NOT short circuit, crush or disassemble.
- 2. Do NOT heat or incinerate.
- 3. Do NOT immerse in any liquid.

4. Store at 50% capacity. Recharge every 6 months. The storage area should be clean, cool, dry and ventilated.

5. Disconnect charging source prior to connecting or disconnecting battery terminals.

6. Do NOT dispose of batteries in a fire as they can explode.

7. Do NOT open, alter, or mutilate batteries. Released electrolyte is harmful to skin and eyes. It may be toxic. 8.Do NOT mix different types and brands of lithium-ion batteries.

 $9.\,Do\,NOT\,dispose$ in trash,follow local regulations and manufacturer's instruction.


10.See installation instructions before connecting to the supply.

11. The battery cabinet receives power from more than one source. Disconnection of all DC sources is required to De-energize this unit before installing or servicing. Wait 5 minutes before opening the unit.


12.Do NOT install on or over combustible surfaces


- 13.Refer to manual before servicing
- 14.Do NOT touch bare terminals.

Charge and Discharge at 25°C,0.5C



Cycle life with DOD at 25°C, 1C/1C





Rack BU614V200(S) BU614V200--without HMI, BU614V200(S)-with HMI