LEOCH PU307V50(307.2V50Ah) PU307V50



LEOCH Provides Safe and Efficient LFP Battery Solutions.

LEOCH PU series adopt high safety LFP cell, with intelligent BMS management system independently developed by LEOCH, safe and reliable, excellent performance, stability and reliability, suitable for three-phase UPS backup system.

Features

- · Safest lithium battery technology
- · Eco-friendly
- · 20 Years Designed service life
- · Can/RS485 Communication output for monitoring
- Achieve up 32 BMU in cascade communication Interal cell balancing, Passive equalization, the
- maximum equalization current up to 300 mA
- \cdot High-precision cell voltage and temperature acquisition: ±3 mV,±1°C
- Fan control circuit and interface, realize heat dissipation inside the module

PACK Style



Peformance data

Time(min)	10	15	20	30	60	
Constant Power(kw)	68.4	60	42	30.2	15.2	
Constant Current(A)	245	200	150	100	50	

Size









System specifications		
Case Material	SPCC	
Cell Type	Prismatic LiFePO ₄	
Terminal Type	M10	
IP Grade	IP21	
Basic performance		
Nominal Voltage	307.2V	
Nominal Capacity	50Ah	
Energy	15.36KWh	
Self Discharge	≤2%/Month	
Cell Capacity	50Ah	
Cycle Life	2500 times(1C/1C)	
Size	1000*600*1500mm	
Weight	350 Kg	

Charge performance		
Rated Charge Current	25A	
Maximum Charge Current	50A	
Rated Charge Voltage	326.4-331.2V	
Balancing Voltage	>326.4V	


Discharge performance		
Max Output Power	68.4KW	
Standard Discharge Time	60KW@15min	
Rated Discharge Cut-off Voltage	268.8V	
Minimum Discharge Cut-off Voltage	254.4V	
Short Circiut Current	Approx.4000A	

Temperature and humidity		
-20-65°C		
0-45°C		
-5-35°C		
-20-65°C		
≤95%R.H		


Other		
Communication	CAN/RS485/LAN	
Dry Contact	Yes	
System Parallels	≤15	
Screen	Optional	
Thermal Management	Air Cooling	



Discharge Performance at 25°C



Temperature effects on capacity at 1C



Cautions

- 1. Do NOT short circuit, crush or disassemble
- 2. Do NOT heat or incinerate.
- 3. Do NOT immerse in any liquid.

4. Store at 50% capacity. Recharge every 6 months. The storage area should be clean, cool, dry and ventilated.

5. Disconnect charging source prior to connecting or disconnecting battery terminals.

6. Do NOT dispose of batteries in a fire as they can explode.

7. Do NOT open, alter, or mutilate batteries. Released electrolyte is harmful to skin and eyes. It may be toxic. 8.Do NOT mix different types and brands of lithium-ion batteries.

9. Do NOT dispose in trash, follow local regulations and manufacturer's instruction.


10.See installation instructions before connecting to the supply.

11. The battery cabinet receives power from more than one source. Disconnection of all DC sources is required to De-energize this unit before installing or servicing. Wait 5 minutes before opening the unit.


12. Do NOT install on or over combustible surfaces

- 13.Refer to manual before servicing
- 14.Do NOT touch bare terminals.

Charge and Discharge at 25°C,0.5C



Cycle life with DOD at 25°C, 1C/1C





Rack PU307V50(S) PU307V50--without HMI, PU307V50(S)-with HMI